



**Department of Public Health & Preventive Medicine**

**SANITARY CERTIFICATE**

**APPENDIX -3 (Chapter III Rule: 24)**

I hereby declare that I have inspected the school **M/S. SENTHOOR VELAN ACADEMY** S.F.NO: 1121/3A2, 1121/3A3 & 1121/3B, DOOR NO:40, VELLAVAVIPUDUR VILLAGE, MOOLANUR (PO), DHARAPURAM TALUK, TIRUPPUR DISTRICT-638661. Building and premises on the day of 28-05-25 and certify that

- The class room and surroundings are maintained neat and clean
- The Sanitary arrangements provided are adequate and satisfactory.
- The Drinking water arrangements provided is satisfactory.

**This Certificate is issued subject to the following conditions:-**

- The Garbage generated within the trust premises should be collected and disposed off Properly by appointing required Sanitary Staff.
- On any Account, the Garbage should not be burnt.
- The children should be educated to prevent the usage of plastics in the School/ Institution premises and no one should bring plastic carry bags, use and throw Tumblers to the School/Institution.
- N.O.C. Should be obtained from the Deputy Director of Health Services, to run a food establishment within in premises.
- Fire precaution measures, and First Aid Box, should be provided.
- Child labor should not be engaged in any account.
- Every person in charge of place of public work should use small display and exhibit a board at a conspicuous place in or outside the place prominently stating that the place is a "No Smoking area. Smoking is an offence" and "Tobacco-Free institution, Sale or offer of cigarettes or other tobacco products is strictly prohibited in the area within a radius of 100 yards" which shall be both in Tamil and English and the version in the second place below the Tamil version.
- This Certificate issued is liable to be cancelled at any time on infringement if any of the above said conditions and for improper maintenance of sanitation, improper maintenance of the building as well as toilets in the institute.
- This Sanitary Certificate valid one year only from the date issue.

Block Health supervisor, (I/C)  
Govt. Primary Health Centre,  
Mulanur

R.NO. 2249  
Countersigned

District Health Officer,  
Tirupur.

To M/S.senthoor Velan Academy, Vellavayiputhur village, Mulanur post - 638661 Dharapuram Taluk, Tiruppur Dt.







# TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

## DISTRICT WATER TESTING LABORATORY

No. 471 & 472, Bharathiyar Complex, Avinashi Road,

Tiruppur – 641602.

Phone: 0421 - 2245201

E-mail: labtpr@gmail.com



TC - 15221

### TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Sample / Lab No:	TR/2025/238	Report Issue Date :	26.05.2025
Invoice Details:	3142/Dt.21.05.2025/ Amt.Rs.1,652 /-		
ULR No:	TC1522125000000118F		

Client Name & Address	:	M/s.Senthoo Velan Academy
Contact No / Email.ID	:	Mallipatti Pirivu, Karur Main Road, Mulanur- 638 661, Dharapuram (TK), Tiruppur.
Sample Name	:	Water- Drinking
Sample Description	:	RO Outlet Water
Sample Code No	:	238
Sample Submitted by	:	Customer-Thiru.T.Vasanthakumar
Location & Date	:	At M/s.Senthoo Velan Academy & 21.05.2025
Quantity of sample Received	:	2 Litre
Sample Container	:	Plastic – Good condition.
Sample Condition on Receipt	:	Good
Sample Received On	:	21.05.2025
Test Commenced on	:	21.05.2025
Test Completed on	:	22.05.2025
Environmental Condition	:	23.0°C-27.0°C

S.No	Parameters	Test Method	Unit	Result	Specification as per IS 10500 : 2012	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	pH @ 25° C	IS 3025 Part 11-2022	--	6.61	6.5-8.5	6.5-8.5
2	Total Alkalinity as CaCO <sub>3</sub>	IS 3025 Part 23-2023	mg/L	20	200	600
3	Total Hardness as CaCO <sub>3</sub>	IS 3025 Part 21-2009 (RA:2023)	mg/L	32	200	600
4	Chloride as Cl	IS 3025-Part 32-1988 (RA:2019)	mg/L	13	250	1000
5	Sulphate as SO <sub>4</sub>	IS 3025-Part 24- Sec 1-2022	mg/L	13	200	400
6	Nitrate as NO <sub>3</sub>	IS 3025-Part 34- Sec 1-2023	mg/L	2	45	45
7	Fluoride as F	IS 3025-Part 60- Sec 1-2023	mg/L	< 0.2	1.0	1.5

**Remarks :** The Tested sample conformed IS:10500:2012 Drinking water specification with respect to above tested Parameters.

..... End of the Report.....

Reviewed & Authorised Signatory  
B .George - Junior Engineer

**Note:**

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.

Issue No./Date	01/01.07.2024	Amend. No/ Date	00/--	Page No	1 of 1
----------------	---------------	-----------------	-------	---------	--------





# TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

## DISTRICT WATER TESTING LABORATORY

No. 471 & 472, Bharathiyar Complex, Avinashi Road,

Tiruppur – 641602.

Phone: 0421 - 2245201

E-mail: labtpr@gmail.com

### TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Sample / Lab No:	TR/2025/238	Report Issue Date :	26.05.2025
Invoice Details:	3142/Dt.21.05.2025/ Amt.Rs.1,652 /-		

S.No	Parameters	Test Method	Unit	Result	Specification as per IS 10500 : 2012	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	Appearance	Physical observation	--	Clear	-	-
2	Colour	IS 3025-Part 4	Hazen	< 2	5	25
3	Odour	IS 3025-Part 5	--	Agreeable	Agreeable	Agreeable
4	Turbidity	IS 3025-Part 10	NTU	< 0.5	1	5
5	Total Dissolved Solids	IS 3025-Part 16	mg/L	69	500	2000
6	Conductivity	IS 3025-Part 14	µS/cm	98	-	-
7	P – Alkalinity as CaCO <sub>3</sub>	IS 3025-Part 23-1983	mg/L	NIL	-	-
8	Calcium as Ca	IS 3025-Part 40	mg/L	6	75	200
9	Magnesium as Mg	IS 3025-Part 46	mg/L	4	30	100
10	Iron as Fe	IS 3025-Part 53	mg/L	< 0.1	0.3	1
11	Manganese as Mn	IS 3025-Part 59	mg/L	< 0.05	0.1	0.3
12	Ammonia as NH <sub>3</sub>	IS 3025-Part 34	mg/L	< 0.1	0.5	0.5
13	Nitrite as NO <sub>2</sub>	IS 3025-Part 34	mg/L	< 0.01	-	-
14	Total Phosphate as PO <sub>4</sub>	IS 3025-Part 31	mg/L	< 0.1	-	-
15	Residual Chlorine	IS 3025-Part 26	mg/L	< 0.2	0.2	1.0
16	Fecal Coliform	IS 1622	CFU/ 100ml	0 / 100ml	0 / 100ml	0/100ml

**Remarks :** The Tested sample conformed IS:10500:2012 Drinking water specification with respect to above tested Parameters.

..... End of the Report.....

*B. George*  
Reviewed & Authorised Signatory  
B .George - Junior Engineer

**Note:**

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.

Issue No./Date	01/01.07.2024	Amend. No/ Date	00/--	Page No	1 of 1
----------------	---------------	-----------------	-------	---------	--------

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION  
CERTIFICATE**

No.

Dated:10.06.2025

It is certified that an inspection team headed by **A.ARULANANDAM , BLOCK HEALTH SUPERVISOR (I/C) from GOVT PRIMARY HEALTH CENTRE, MULANUR** inspected the **SENTHOOR VELAN ACADEMY S.F.NO : 1121/3A2,1121/3A3 & 1121/3B ,VELLAVAVIPUDUR VILLAGE, MULANUR POST OFFICE – 638661 ,DHARAPURAM (TK), TIRUPPUR (DT)** on **10.06.2025** and on the basis of Water Test Report (Attached) bearing no **DWTL/FORM/7.8/01** dated **26.05.2025** of **DISTRICT WATER TESTING LABORTARY TIRUPPUR** certified that the **SENTHOOR VELAN ACADEMY** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt. This certificate is valid till **ONE YEAR**

  
**BLOCK HEALTH SUPERVISOR (I/C),**

**GOVT PRIMARY HEALTH CENTRE,**

**MULANUR**

**TO**

**SENTHOOR VELAN ACADEMY,  
MALLIPATTI PIRIVU,  
KARUR MAIN ROAD,  
MULANUR, DHARAPURAM (TK),  
TIRUPPUR (DT)- 638 661**